FIRESTOP SCHEDULE (PER LEVEL: L2)

TAG	WALL	RATING	PENETRANT	LISTED SYSTEM	F / T	ANNULAR (LISTED)	FILL	PER LEVEL	TOTAL
P1	CW-1	1 HR	8 IN ROUND GALVANIZED STEEL DUCT	UL W-L-7229	F 1 HR, T 0 HR	0 TO 1 IN	MIN 0.5 IN	16	46
P2	CW-1	1 HR	1 IN CPVC PIPE	UL W-L-2413	F 1 HR, T 0 HR	0 TO 0.625 IN	MIN 0.625 IN	16	46

LISTED SYSTEMS

SYSTEM	PENETRANT (LISTED)	WALL (TESTED)	MAX OPENING	BASIS OF DESIGN	LISTING PAGE
UL W-L-7229	STEEL DUCT TO NOM 10 IN	U300, U400, V400, W400 SERIES, WOOD STUDS NOM 2 BY 4 IN. AT 16 IN. OC	11 IN	RECTORSEAL METACAULK 1000 IN UL SYSTEM W-L-7229	https://apps.rectorseal.com/fsg/systems/XHEZ.W-L-7229
UL W-L-2413	CPVC PIPE TO NOM 2 IN	U300, U400, V400, W400 SERIES, WOOD STUDS NOM 2 BY 4 IN. AT 16 IN. OC	3 IN	RECTORSEAL METACAULK 1000 IN UL SYSTEM W-L-2413	https://apps.rectorseal.com/fsg/systems/XHEZ.W-L-2413

NOTES

1. THE OPENING IS CUT ON SITE: ITS SIZE IS NOT PROVIDED HERE, AND THE INSTALLER HOLDS THE ANNULAR SPACE TO THE LISTED RANGE ABOVE.
2. F EQUALS THE WALL'S RATING IN BOTH LISTINGS. THE WALL'S REQUIRED RATING IS TAKEN AS ITS TYPE'S OWN RATING ON A5.1 AND A5.4.
3. EACH LISTING ASKS FOR THE PENETRANT RIGIDLY SUPPORTED ON BOTH SIDES OF THE WALL AND FOR FILL TO THE MINIMUM DEPTH ABOVE. THE STEEL DUCT LISTING ALSO SETS A MINIMUM GAUGE AND THE CPVC LISTING A PIPE SDR. THE ROUTER NAMES NONE OF THESE; THE INSTALLER MUST CHECK EACH ON SITE.
4. SYSTEM PAGES ARE RECTORSEAL'S REPRINTS OF THE UL ONLINE CERTIFICATIONS DIRECTORY. UL PRODUCT IQ NEEDS A LOGIN AND WAS NOT READ; THE FIRESTOP DESIGNER MUST VERIFY THE CURRENT LISTING.
5. A SUBSTITUTE IS ANOTHER LISTED SYSTEM FOR THE SAME PENETRANT, WALL AND RATING, SUBMITTED UNDER SECTION 07 84 00 WITH ITS SYSTEM SHEET.
6. TAGS WITH THE LITERAL HAVE NO LISTED SYSTEM IN THE FIRESTOP ROWS. THE FIRESTOP DESIGNER NAMES ONE, OR AN ENGINEERING JUDGMENT, FOR EACH.

① **FIRESTOP SCHEDULE**
SCALE: NTS

SHEET NOTES

1. FIRESTOPPING: SPECIFIED IN SECTION 07 84 00.

NOT PROVIDED — BY OTHERS
APPLICANT / OWNER

CONSULTANTS

STRUCTURAL	NOT PROVIDED — BY OTHERS
CIVIL	NOT PROVIDED — BY OTHERS
MECHANICAL	NOT PROVIDED — BY OTHERS
PLUMBING	NOT PROVIDED — BY OTHERS
ELECTRICAL	NOT PROVIDED — BY OTHERS
LANDSCAPE	NOT PROVIDED — BY OTHERS
FIRE PROTECTION	NOT PROVIDED — BY OTHERS
GEOTECHNICAL	NOT PROVIDED — BY OTHERS

REVIEW
Prepared for review by the design professional of record. Not for construction or permit submission.

PROJECT

Architecture.Engineering — L courtyard study
FICTIONAL STUDY: NO REAL PARCEL
ARCHITECTURE.ENGINEERING — L COURTYARD STUDY
OCCUPANCY R-2, M · CONSTRUCTION NOT PROVIDED — BY OTHERS · STORIES 4

REVISIONS

MARK	DATE	DESCRIPTION

REGISTER

Project	AE-STUDY-L01
Issue	NOT PROVIDED — BY OTHERS
Date	NOT PROVIDED — BY OTHERS
Drawn	NOT PROVIDED — BY OTHERS
Scale	NTS
Phase	CONSTRUCTION DOCUMENTS

OPEN ISSUE
The set's open issue is stated on the cover, G0.01.

FIRESTOP SCHEDULE

SHEET
G0.20