THIRTEEN INSTRUMENTS: 6 WITH OFFENDERS, 1 NOT EVALUATED, 6 CLEAN

NO.	CHECK	EXIT	VERDICT	READ	FIRST OFFENDER, OR WHAT THE CHECK COULD NOT READ
QA-001	SHEETS MISSING FROM THE INDEX	0	CLEAN	130	NONE
QA-002	UNREFERENCED CALLOUTS	1	60 OFFENDERS	70	A1.01: SECTION A NAMES A4.1; A4.1 DRAWS NO SECTION A
QA-003	TAGS WITH NO ELEMENT	0	CLEAN	227	NONE
QA-004	SCHEDULES THAT DISAGREE WITH THE ELEMENT FILE	0	CLEAN	552	NONE
QA-005	DIMENSIONS THAT DO NOT CLOSE	1	17 OFFENDERS	55	A1.02#4: PARTS 90 + 6 + 41 + 5 + 123 = 265 IN; THE OVERALL PRINTS 264 IN (+1 IN)
QA-006	ROOMS WITHOUT FINISHES	1	6 OFFENDERS	314	BUILDING SERVICES ROOM (COMMON): NO FINISH SCHEDULE ROW NAMES THIS ROOM; 3 IN THE ELEMENT FILE
QA-007	DOORS WITHOUT HARDWARE	0	CLEAN	406	NONE
QA-008	DETAILS NOT REFERENCED	1	29 OFFENDERS	29	1/A3.5: NO CALLOUT ON ANY SHEET NAMES THIS DETAIL
QA-009	REVISIONS NOT CLOUDED	2	NOT EVALUATED	0	THE IBG CARRIES NO REVISIONS RECORD, SO THERE IS NO CHANGE TO LOOK FOR A CLOUD ON
QA-010	OVERLAPPING ELEMENTS	0	CLEAN	451	NONE
QA-011	UNENCLOSED ROOMS	1	8 OFFENDERS	84	ROOM:L1:01: NORTH SIDE OPEN 6.50 FT AT 24.95 TO 31.45; NORTH SIDE OPEN 6.83 FT AT 183.90 TO 190.73; SOUTH SIDE OPEN 6.50 FT AT 24.95 TO 31.45
QA-012	UNJOINED WALLS	1	6 OFFENDERS	734	WALL:L2-MAIN:CORRIDOR-NORTH: END AT (184.53, 31.20) MEETS NO WALL; WALL:L2:SHARED-C06-WEST IS 0.62 FT AWAY
QA-013	ELEMENT ON NO LEVEL	0	CLEAN	1300	NONE

OFFENDERS, THE FIRST 2 OF EACH INSTRUMENT

NO.	AT	WHY
QA-002	A1.01	SECTION A NAMES A4.1; A4.1 DRAWS NO SECTION A
QA-002	A1.01	SECTION B NAMES ---, WHICH IS NOT IN THIS SET
		AND 58 MORE IN SET-QA.JSON AND RECORD QA-002
QA-005	A1.02#4	PARTS 90 + 6 + 41 + 5 + 123 = 265 IN; THE OVERALL PRINTS 264 IN (+1 IN)
QA-005	A1.02#5	PARTS 90 + 6 + 36 + 29 + 4 + 218 = 383 IN; THE OVERALL PRINTS 384 IN (-1 IN)
		AND 15 MORE IN SET-QA.JSON AND RECORD QA-005
QA-006	BUILDING SERVICES ROOM (COMMON)	NO FINISH SCHEDULE ROW NAMES THIS ROOM; 3 IN THE ELEMENT FILE
QA-006	RESIDENT LOUNGE (COMMON)	NO FINISH SCHEDULE ROW NAMES THIS ROOM; 3 IN THE ELEMENT FILE
		AND 4 MORE IN SET-QA.JSON AND RECORD QA-006
QA-008	1/A3.5	NO CALLOUT ON ANY SHEET NAMES THIS DETAIL
QA-008	2/A3.5	NO CALLOUT ON ANY SHEET NAMES THIS DETAIL
		AND 27 MORE IN SET-QA.JSON AND RECORD QA-008
QA-011	ROOM:L1:01	NORTH SIDE OPEN 6.50 FT AT 24.95 TO 31.45; NORTH SIDE OPEN 6.83 FT AT 183.90 TO 190.73; SOUTH SIDE OPEN 6.50 FT AT 24.95 TO 31.45
QA-011	ROOM:L1:06	EAST SIDE OPEN 6.83 FT AT 24.95 TO 31.78; WEST SIDE OPEN 6.50 FT AT 24.95 TO 31.45
		AND 6 MORE IN SET-QA.JSON AND RECORD QA-011
QA-012	WALL:L2-MAIN:CORRIDOR-NORTH	END AT (184.53, 31.20) MEETS NO WALL; WALL:L2:SHARED-C06-WEST IS 0.62 FT AWAY
QA-012	WALL:L2-MAIN:CORRIDOR-NORTH:SPAN-2	END AT (190.03, 31.20) MEETS NO WALL; WALL:L2-MAIN:SHAFT-CORE-A-2-WEST IS 0.71 FT AWAY
		AND 4 MORE IN SET-QA.JSON AND RECORD QA-012

NOTES

1. EXIT 0 IS CLEAN, 1 NAMES EACH OFFENDER, 2 NAMES WHAT THE SET OR THE ELEMENT FILE DOES NOT CARRY. A CHECK WITH NOTHING TO READ IS NOT EVALUATED, NEVER CLEAN.
2. QA-001 TO QA-009 READ WHAT THE RENDERERS RECORDED WHILE DRAWING THIS SET, BESIDE THE ELEMENT FILE THE SAME MODEL BUILDS. QA-010 TO QA-013 ARE THE WARNINGS LIST AND READ THE ELEMENT FILE ALONE.
3. THE RESULTS DO NOT STOP THE BUILD. THEY ARE PRINTED HERE AND WRITTEN TO SET-QA.JSON AND THE LEDGER; A REVIEWER CLEARS EACH OFFENDER ON THE DRAWINGS, OR IN THE MODEL, AND RE-RUNS ITS SCRIPT.
4. THE REVIEWER READS THIS SHEET AS A RECEIPT. IT DRAWS NO TAG, CALLOUT, DIMENSION OR SCHEDULE ROW THE CHECKS READ, SO ITS OWN PRESENCE CHANGES NO RESULT.
5. QA-001 IS PLAN-SET-STANDARD SECTION 8 CHECK 1. CHECKS 2, 7 AND 8 OF THAT SECTION RUN IN TOOLS/CHECKS/PLAN_SET_CHECKS.PY; QA-003 READS CHECK 8'S TAGS AGAINST THE ELEMENT FILE INSTEAD OF THE SCHEDULES.

1 SET QA AND MODEL WARNINGS
SCALE: NTS

SHEET NOTES

1. GENERAL REQUIREMENTS: SPECIFIED IN SECTION 01 10 00.

NOT PROVIDED — BY OTHERS
APPLICANT / OWNER

CONSULTANTS

STRUCTURAL	NOT PROVIDED — BY OTHERS
CIVIL	NOT PROVIDED — BY OTHERS
MECHANICAL	NOT PROVIDED — BY OTHERS
PLUMBING	NOT PROVIDED — BY OTHERS
ELECTRICAL	NOT PROVIDED — BY OTHERS
LANDSCAPE	NOT PROVIDED — BY OTHERS
FIRE PROTECTION	NOT PROVIDED — BY OTHERS
GEOTECHNICAL	NOT PROVIDED — BY OTHERS

REVIEW

Prepared for review by the design professional of record. Not for construction or permit submission.

PROJECT

Architecture.Engineering — L courtyard study

FICTIONAL STUDY; NO REAL PARCEL
ARCHITECTUREENGINEERING — L COURTYARD STUDY
OCCUPANCY R-2, M · CONSTRUCTION NOT PROVIDED — BY OTHERS · STORIES 4

REVISIONS

MARK	DATE	DESCRIPTION

REGISTER

Project	AE-STUDY-L01
Issue	NOT PROVIDED — BY OTHERS
Date	NOT PROVIDED — BY OTHERS
Drawn	NOT PROVIDED — BY OTHERS
Scale	NTS
Phase	CONSTRUCTION DOCUMENTS

OPEN ISSUE

The set's open issue is stated on the cover, G0.01.

SET QA AND MODEL WARNINGS

SHEET

G0.22