
1 METAL PANEL EXTERIOR WALL SECTION

SCALE: 3" = 1'-0"

0" 3" 6" 9" 1'-0"



BUILD-UP

01 METAL PANEL (0.040" GAUGE ALUMINUM) - 0"
02 Z-GIRT SUBFRAME - 1 1/2"
03 WEATHER-RESISTIVE BARRIER (WRB) - 0"
04 2" RIGID INSULATION (R-10) - 2"
05 7/16" OSB SHEATHING - 1/2"
06 2x6 WOOD STUDS @ 16" O.C. W/ R-21 BATT INSULATION - 5 1/2"
07 6 MIL POLYETHYLENE VAPOR BARRIER - 0"
08 5/8" TYPE X GYPSUM WALLBOARD - 5/8"

PERFORMANCE

R-33.0 | STC 45 | 1-HR | TOTAL 10 1/8"

ANNOTATIONS

CONCEALED FASTENER CLIP SYSTEM
Z-GIRT THERMAL BREAK AT EACH ATTACHMENT
PANEL JOINTS: STANDING SEAM OR LAPPED, SEALED


NOTES

1. INSTALLER: METAL PANELS: 0.040" ALUMINUM OR 22-GA STEEL, KYNAR FINISH.
2. INSTALLER: Z-GIRTS TO PROVIDE THERMAL BREAK BETWEEN PANEL AND SHEATHING.
3. INSTALLER: CONTINUOUS INSULATION OUTBOARD OF SHEATHING PER ENERGY CODE.
4. INSTALLER: PANEL COLOR AND PROFILE PER ARCHITECTURAL ELEVATIONS.
5. INSTALLER: SEALANT AT ALL PANEL JOINTS: TREMCO DYMONIC 100 OR EQUAL.

2 THREE-COAT STUCCO EXTERIOR WALL SECTION

SCALE: 3" = 1'-0"

0" 3" 6" 9" 1'-0"



BUILD-UP

01 3-COAT STUCCO (7/8" TOTAL) - 7/8"
02 GALVANIZED METAL LATH (3.4 LB/SY) - 0"
03 TWO LAYERS GRADE D BUILDING PAPER - 1/8"
04 7/16" OSB SHEATHING - 1/2"
05 2x6 WOOD STUDS @ 16" O.C. W/ R-21 BATT INSULATION - 5 1/2"
06 6 MIL POLYETHYLENE VAPOR BARRIER - 0"
07 5/8" TYPE X GYPSUM WALLBOARD - 5/8"

PERFORMANCE

R-26.0 | STC 46 | 1-HR | TOTAL 7 5/8"

ANNOTATIONS

CONTROL JOINTS @ 144 SF MAX PANEL AREA
EXPANSION JOINTS AT FLOOR LINES AND COLUMN LINES
WEEP SCREED AT BASE OF STUCCO ABOVE GRADE

NOTES

1. INSTALLER: STUCCO MIX: 1:3 CEMENT/SAND (SCRATCH & BROWN), FINISH COAT PER ARCHITECT.
2. INSTALLER: SCRATCH COAT: 3/8", BROWN COAT: 3/8", FINISH: 1/8".
3. INSTALLER: METAL LATH: 3.4 LB/SY GALVANIZED, EXPANDED METAL.
4. INSTALLER: BUILDING PAPER: 2 LAYERS GRADE D, 60-MIN, LAPPED 6" MIN.
5. INSTALLER: CONTROL JOINTS PER ASTM C1063.

SHEET NOTES

1. WALL SECTION: SPECIFIED IN SECTIONS 06 10 00, 07 21 00, 09 21 00, 07 46 00, 07 52 00.

NOT PROVIDED — BY OTHERS
APPLICANT / OWNER

CONSULTANTS

STRUCTURAL	NOT PROVIDED — BY OTHERS
CIVIL	NOT PROVIDED — BY OTHERS
MECHANICAL	NOT PROVIDED — BY OTHERS
PLUMBING	NOT PROVIDED — BY OTHERS
ELECTRICAL	NOT PROVIDED — BY OTHERS
LANDSCAPE	NOT PROVIDED — BY OTHERS
FIRE PROTECTION	NOT PROVIDED — BY OTHERS
GEOTECHNICAL	NOT PROVIDED — BY OTHERS

REVIEW

Prepared for review by the design professional of record. Not for construction or permit submission.

PROJECT

Architecture.Engineering — L courtyard study

FICTIONAL STUDY: NO REAL PARCEL
ARCHITECTUREENGINEERING — L COURTYARD STUDY
OCCUPANCY R-2, M · CONSTRUCTION NOT PROVIDED — BY OTHERS · STORIES 4

REVISIONS

MARK	DATE	DESCRIPTION

REGISTER

Project	AE-STUDY-L01
Issue	NOT PROVIDED — BY OTHERS
Date	NOT PROVIDED — BY OTHERS
Drawn	NOT PROVIDED — BY OTHERS
Scale	1-1/2"
Phase	CONSTRUCTION DOCUMENTS

OPEN ISSUE

The set's open issue is stated on the cover, G0.01.

WALL SECTIONS — METAL PANEL EXTERIOR WALL SECTION, THREE-COAT STUCCO EXTERIOR WALL SECTION

SHEET

A5.6